


DESIGN AND FABRICATION OF A SHELL AND TUBE HEAT EXCHANGER THAT USES EXHAUST GAS TO RAISE THE TEMPERATURE OF WATER.

SALIU ISIAKA NASIR

NOVEMBER 2017



CERTIFICATION

This is to certify that this project was carried out by SALIU ISIAKA NASIR, a student of Mechanical Engineering, Faculty of Engineering, Federal University Oye Ekiti, Ekiti State.

PROF. ENGR. B. OBOLAJI

.....

PROJECT SUPERVISOR

SIGNATURE AND DATE

DR ADELEKE

..... *E. Adeleke 20/1/17*

HEAD OF DEPARTMENT

SIGNATURE AND DATE

PROF. ABOLARINWA

..... *Abolarinwa 9/1/17*

EXTERNAL SUPERVISOR

SIGNATURE AND DATE



STUDENT'S DECLARATION

I declare that the work in this project is as a result of my findings and analysis in the process of designing the project. It has not been submitted in candidature of any student in any university. All works that has been benefited from are all duly acknowledged and referenced.

Signature: .....

Name: SALIU ISIAKA NASIR

Matriculation Number: MEE/12/0868

Date: November 2017

ACKNOWLEDGEMENT

I am grateful and would like to express my warmest gratitude to my supervisors PROF.ENGR. B.O BOLAJI and my co- supervisor DR. OYELARAN for their guidance, his support, continuous encouragement and the confidence he has shown in me over the years in making this research possible.

His constant encouragement in my dissertation work that helped to look forward to the future with enthusiasm and confidence in my abilities. I would like also to express my sincere thanks to all my course mates and members of the staff of the Mechanical Engineering Department, FUOYE, who helped me in many ways and made my stay at FUOYE pleasant and unforgettable.

I acknowledge my sincere indebtedness and gratitude to my parents for their love, dream and sacrifice throughout my life. I cannot find the appropriate words that could properly describe my appreciation for their devotion, support and faith in my ability to attain my goals. To my brother and uncle who are really helpful in supporting me mentally.

Finally, I would like to thank my friends, for their support both emotionally and Financially, in completing this endeavor. I sincerely appreciate their patience and understanding while waiting for me to complete our project. . I would like to acknowledge, their comments and suggestions, which was crucial for the successful completion of this study. Without their overwhelming positive influence on my project, I would not have been able to achieve our goals.

ABSTRACT

This project is mainly focusing on designing one type of a heat exchanger which is shell and tube heat exchanger. Step by step on designing, analysis was done with the use of the effective NTU method. This method is technically simpler than LMTD where it has to refer to a complex graph to calculate certain outputs that needed. The software used is ANSYS 14. The language in the program consists of formulas of calculating parameters in heat exchanger such as heat transfer coefficient, heat transfer rate or heat capacity rate. This program design should match the heat exchanger software in the market. To design this heat exchanger, many considerations were taken. The shell size must be adaptable to the water flow rate. To determine how many tubes that are used also depends on the size of the shell. Water flow rate can be determined by using ball valve opening. To read the temperature, a thermometer digital is attached at inlet and outlet for both hot and cold fluid. The manual calculation is done to check the program in the software whether it is compatible. We used the exhaust gases from the generator used in ikole campus to raise the temperature of water. This was achieved after rigorous activities of analysis.



Contents

CERTIFICATION	II
STUDENT'S DECLARATION.....	III
ACKNOWLEDGEMENT	IV
ABSTRACT.....	V
CHAPTER ONE.....	1
INTRODUCTION	1
1.1 BACKGROUND OF THE STUDY	1
1.2 AIMS AND OBJECTIVE OF THE PROJECT	2
1.2 JUSTIFICATION OF THE STUDY.....	3
1.3 PROBLEM STATEMENT	3
CHAPTER TWO.....	5
2.1 INTRODUCTION.....	5
2.2 USES AND APPLICATIONS OF HEAT EXCHANGER.....	5
2.3 TYPE OF HEAT EXCHANGERS	6
2.3.1 TUBULAR HEAT EXCHANGERS	7
2.3.1.1 DOUBLE-PIPE HEAT EXCHANGER.....	7
2.3.1.2 SHELL-AND-TUBE HEAT EXCHANGER	8
2.3.1.3 SPIRAL-TUBE HEAT EXCHANGER	9
2.3.2 PLATE HEAT EXCHANGERS	10
2.3.2.1 GASKETED PLATE HEAT EXCHANGERS	11
2.3.2.2 SPIRAL PLATE HEAT EXCHANGER	12
2.3.2.3 LAMELLA HEAT EXCHANGERS	14
2.4 SHELL AND TUBE HEAT EXCHANGER.....	15
2.4.1 SHELL	15
2.4.2 TUBE	16
2.4.3 BAFFLE.....	17
MATERIALS AND METHODS	19
3.1 MATRIALS	19
3.2 Methods	20
3.2.1Modelling of the exhaust	22
3.2.2 DESIGN CALCULATIONS.....	22
3.4.1 SPECIFICATIONS FOR PUMP	22

3.4.2	DESIGN FOR SHELL	25
3.4.3	DESIGN FOR FOULING FACTOR (TUBE).....	28
3.4.3	DESIGN FOR INSULATION	29
CHAPTER FOUR		30
	Result and discussion	30
4.1	RESULT.....	30
4.2	Discussion	32
CHAPTER FIVE.....		33
	Conclusion and recommendation	33
5.1	Conclusion	33
5.2	Recommendation.....	33
REFERENCES		34

CHAPTER ONE

INTRODUCTION

1.1 BACKGROUND OF THE STUDY

Heat exchanger is a device built for efficient heat transfer from one medium to another, whether the media are separated by a solid wall so that they never mix, or the media are in direct contact, or a heat exchanger is a heat-transfer device that is used for transfer of internal thermal energy between two or more fluids available at different temperatures. In most heat exchangers, the fluids are separated by a heat-transfer surface, and ideally they do not mix.

They are widely used in space heating, refrigeration, air conditioning, power plants, chemical plants, petrochemical plants, petroleum refineries, and natural gas processing. One common example of a heat exchanger is the radiator in a car, in which a hot engine-cooling fluid, like antifreeze, transfers heat to air flowing through the radiator. To design a heat exchanger, many criteria have to be taken before making any decision. From there, the software runs and the main point is to create a new windows program that is similar to another existed software of calculating heat transfer in market. The major purpose is to obtain a desired output by using this program. Thus, the ideal shell and tube heat exchanger is produced at the end. Heat Exchanger is a device which provides a flow of thermal energy between two or more fluids at different temperatures. Heat exchangers are used in a wide variety of engineering applications like power generation, waste heat recovery, manufacturing industry, air-conditioning, refrigeration, space applications, petrochemical industries etc. Heat exchanger may be classified according to the following main criteria.

1. Recuperators and Regenerators.

2. Transfer process: Direct contact and Indirect contact.
3. Geometry of construction: tubes, plates and extended surfaces.
4. Heat transfer mechanisms: single phase and two phase.
5. Flow arrangements: parallel, counter and cross flows.

Shell and tube heat exchangers are most versatile type of heat exchanger; they are used in process industries, in conventional and nuclear power station as condenser, in steam generators in pressurized water reactor power plants, in feed water heaters and in some air conditioning refrigeration systems.

Shell and tube heat exchanger provide relatively large ratio of heat transfer area to volume and weight and they can be easily cleaned. Shell and tube heat exchanger offer great flexibility to meet almost any service requirement. Shell and tube heat exchanger can be designed for high pressure relative to the environment and high pressure difference between the fluid streams. **Basic Components of Shell and Tube Heat Exchanger.**

Shell and tube heat exchanger are built of round tubes mounted in a cylindrical shell with the tubes parallel to the shell. One fluid flow inside the tubes, while the other fluid flows across and along the axis of the exchanger, the major components of this exchanger are tubes (tube bundles), shell, front end head, rear end head, baffles and tube sheets.

1.2 AIMS AND OBJECTIVE OF THE PROJECT

The aim of the study is to:

- Develop an apparatus that can be of use in Fuoye for the generator by recycling the exhaust gases to raise the temperature of water

The objectives of this project are:

- i) To design and simulate a shell and tube type heat exchanger using ANSYS software.
- ii) To design the heat exchanger that uses exhaust gases from generator to raise the temperature of water.
- iii) To design and build a small shell and tube heat exchanger to check the specification.

1.2 JUSTIFICATION OF THE STUDY

The project helps in revealing the ingenuity in the engineering field and helps to realize the beauty of engineering field

The project solves real life problem in restoring the eco system to a balanced one.

The project also helps in the renewable of heat that is supposed to be lost

The project will in the long run helps to increase the life span of the generator and this will reduce the failure rate.

1.3 PROBLEM STATEMENT

The shell and tube heat exchanger is one type of heat exchanger that is common used in industry. This is because it contains a large number of tubes packed in a shell with the axis parallel to that shell. There is a heat transferred when one fluid flows inside the tubes and other fluid flows outside the tubes through the shell. In reality, shell and tube heat exchanger is not suitable for use in aircraft and automotive purposes because the size is relatively large and also weighty. In this project, the main focus is in designing a small shell and tube heat exchanger which is available and easy to do an experiment in the lab. There is a choice of formula to utilize in defining the desired outputs. We can use the LMTD (Log Mean Temperature Difference) or ϵ -NTU (effectiveness-Number of

Transfer Units). The method used in constructing the formula is using ϵ -NTU which is introduced in 1955 by Kays and London. This method is more greatly simplified heat exchanger analysis than LMTD. In this project, the problem stated are to check if the design is worked and is it possibly compatible with the software.

CHAPTER TWO

2.1 INTRODUCTION

Heat exchanger is one of devices that is convenient in industrial and household application. These include power production, chemical industries, food industries, electronics, environmental engineering, manufacturing industry, and many others. It comes in many types and function according to its uses.

Heat exchanger is a device that is used to transfer thermal energy between two or more fluids, between a solid surface and a fluid at different temperatures and in thermal contact. There are usually no external heat and work interactions. In most heat exchangers, heat transfer between fluids takes place through a separating wall or into and out of a wall in a transient manner. (Shah R.K., 2003)

This chapter will discuss about the uses and application of shell and tube heat exchanger, type of heat exchangers, and shell and tube heat exchanger.

2.2 USES AND APPLICATIONS OF HEAT EXCHANGER

Heat exchangers are used to transfer heat from one media to another. It is most commonly used in space heating such as in the home, refrigeration, power plants and even in air conditioning. It is also used in the radiator in a car using an antifreeze engine cooling fluid. Heat exchangers are classified according to their flow arrangements where there are the parallel flow, and the counter flow. Aside from this, heat exchangers also have different types depending on their purpose and how that heat is exchanged. Heat exchangers in large scale industrial processes are usually custom made to suit the process, depending on the type of fluid used, the phase, temperature, pressure, chemical composition and other thermodynamic properties. (Kakac, S. 2002).

Heat exchangers mostly can be found in industries which produce a heat stream. In this case, heat exchangers usually circulate the output heat to put it as input by heating a different stream in the process. The fact that it really saves a lot of money because when the output heat no longer needed then it can be recycled rather than to come from an external source as heat is basically recycled. When used in industries and in the home, it can serve to lower energy costs as it helps recover wasted heat and recycle it for heating in another process. Typically, most heat exchangers use fluid to store heat and heat transfer can take the form of either absorption or dissipation. For instance, heat exchangers are used as oil coolers, transmission and engine coolers, boiler coolers, waste water heat recovery, condensers and evaporators in refrigeration systems. In residential homes, heat exchangers are used for floor heating, pool heating, snow and ice melting, domestic water heater, central, solar and geothermal heating. Of course, heat exchangers have different designs which depend on the purpose it is intended for. Brazed heat exchangers, a collection of plates which are brazed together, are used for hydronic systems like swimming pools, floor heating, snow and ice melting. The shell and coil heat exchanger design is best for areas with limited spaces as it can be installed vertically.

2.3 TYPE OF HEAT EXCHANGERS

Different heat transfer applications require different types of hardware and different configurations of heat transfer equipment. The attempt to match the heat transfer hardware to the heat transfer requirements within the specified constraints has resulted in numerous types of innovative heat exchanger designs.

2.3.1 TUBULAR HEAT EXCHANGERS

The tubular types are consists of circular tubes. One fluid flows inside the tubes and the other flows on the outside of the tubes. The parameters of the heat exchanger can be changed like the tube diameter, the number of pitch, tube arrangement, number of tubes and length of the tube can be manipulate. The common type of heat exchangers lie under this categories are double-pipe type, shell-and-tube type and spiral tube type. The tubular heat exchangers can be designed for high pressure relative to the environment and high pressure difference between the fluids. These exchangers are used for liquid-to-liquid and liquid-to-vapor phase. But when the operating temperature or pressure is very high or fouling on one fluid side, it will used gas-to-liquid and gas-togas heat transfer applications.

2.3.1.1 DOUBLE-PIPE HEAT EXCHANGER

According to SadicKakac, a double-pipe heat exchanger consists of smaller and larger diameter pipe where the smaller pipe fitted concentrically into the larger one in purpose to give direction to the flow from one section to another. One set of these tubes includes the fluid that has to be cooled or heated. The second fluid runs over the tubes being cooled or heated in order to provide heat or absorb the heat. A set of tubes is the tube bundle and it can be made up of several types of tubes such as longitudinally plain, longitudinally finned, and more. If the application requires an almost constant wall temperature, the fluids may flow in a parallel direction. It's easy to clean and convenient to disassemble and assemble. The double-pipe heat exchanger is one of the simplest. Usually, it is used for small capacity applications because it is so expensive on a cost per unit area basis. Figure 2.1 presents the model of double-pipe heat exchanger.




Plate 2.1: double-pipe heat exchanger
Source: Ritai China

2.5.2 SHELL-AND-TUBE HEAT EXCHANGER

The most common type of heat exchanger in industrial applications is the shell-and-tube heat exchanger, shown in Figure 2.2. Shell-and-tube heat exchangers contain a large number of tubes (sometimes several hundred) packed in a shell with their axes parallel to that of the shell. Heat transfer takes place as one fluid flows inside the tubes while the other fluid flows outside the tubes through the shell. Baffles are commonly placed in the shell to force the shell-side fluid to flow across the shell to enhance heat transfer and to maintain uniform spacing between the tubes. Despite their widespread use, shell and-tube heat exchangers are not suitable for use in automotive and aircraft applications because of their relatively large size and weight. Note that the tubes in a shell-and-tube heat exchanger open to some large flow areas called headers at both ends of the shell, where the tube-side fluid accumulates before entering the tubes and after leaving them. Shell-and-tube heat exchangers are further classified according to the number of shell and tube passes involved. Heat exchangers in which all the tubes make one U-turn in the shell, for example, are called *one-shell-pass and two tube-passes* heat

exchangers. Likewise, a heat exchanger that involves two passes in the shell and four passes in the tubes is called a two-shell-passes and four-tube-passes heat exchanger

The figure 2.2 shows the type of shell-and-tube heat exchanger.




Figure 2.2: U-tube shell and tube heat exchanger

Source: API Heat Transfer

2.3.1.3 SPIRAL-TUBE HEAT EXCHANGER

A spiral heat exchanger is a helical or coiled tube configuration. It consists of spirally wound coils placed in a shell or designed as co-axial condensers and co-axial evaporators that are used in refrigeration systems. The heat transfer coefficient is higher in a spiral tube than in a straight tube. Since the cleaning is impossible, the spiral tubes are suitable for thermal expansion and clean fluids. The biggest advantage of the spiral heat exchanger is its efficient use of space. A compact spiral heat exchanger can lower costs, while an oversized one can have less pressure drop, higher thermal efficiency, less pumping energy, and lower energy costs. Spiral heat exchangers are frequently used when heating fluids that have solids and therefore often foul the inside of the heat exchanger. Spiral heat exchangers have three types of flow arrangements.

Firstly, the spiral flow and cross flow has one fluid in each. The spiral flow passages are welded at each side and this type of flow is good for handling low density gases which pass through the cross flow. This can be used for liquid-to-liquid applications if one fluid has a much greater flow rate than the other. A second type is the distributed vapor and spiral flow. The coolant moves in a spiral and exits through the top. The hot gases that enter will leave as condensate out of the bottom outlet. The third type is the countercurrent flow where both of the fluids will flow in opposite directions and are used for liquid-to-liquid applications. The spiral heat exchanger is good for pasteurization, heat recovery, digester heating, effluent cooling, and pre-heating. Figure 2.3 presents the spiral-tube heat exchanger.




Plate 2.3: Spiral tube heat exchanger

2.5.2 PLATE HEAT EXCHANGERS

A second type of heat exchanger is a plate heat exchanger. It has many thin plates that are slightly apart and have very large surface areas and fluid flow passages that are good for heat transfer. This can be a more effective heat exchanger than the tube or shell heat exchanger due to advances in brazing and gasket technology that have made this plate exchanger more practical. Large heat

exchangers are called plate and frame heat exchangers and they allow for periodic disassembly, cleaning, and inspection. There are several types of permanently bonded plate heat exchangers like dip brazed and vacuum brazed plate varieties, and they are often used in refrigeration. These heat exchangers can further be classified as gasketed plate, spiral plate and lamella.

2.3.2.1 GASKETED PLATE HEAT EXCHANGERS

A gasketed plate heat exchanger consists of a series of thin plates that have wavy surface which function as separating the fluids. The plates come with corner parts arranged so that the two media between which heat is to be exchanged flow through interchange exclaim spaces. Appropriate design and gasketing permit a stack of plates to be held together by compression bolts joining the end plates. Gaskets prevent leakage to the outside and direct the fluids in the plates as desired. The flow pattern is generally chosen so that the media flow countercurrent to each other. Since the flow passages are quite small, strong eddying gives high heat transfer coefficients, high pressure drops, and high local shear which minimizes fouling. These exchangers provide a relatively compact and lightweight heat transfer surface. Gasketed plate are typically used for heat exchange between two liquid streams. This type can be found in food processing industries because of the compatibility to be cleaned easily and sterilized as it completely disassembled. Figure 2.4 presents the gasketed plate heat exchanger.




Plate 2.4: Gasketed plate heat exchanger

2.3.1.2 SPIRAL PLATE HEAT EXCHANGER

Spiral heat exchangers are formed by rolling two long, parallel plates into a spiral using a mandrel and welding the edges of adjacent plates to form channels. The distance between the metal surfaces in both channels is maintained by means of distance pins welded to the metal sheet. The two spiral paths introduce a secondary flow, increasing the heat transfer and reducing fouling deposits. These heat exchangers are quite compact but are relatively expensive due to the specialized fabrication. The spiral heat exchanger is particularly effective in handling sludges, viscous liquids, and liquids with solids in suspension including slurries. The spiral heat exchanger is made in three main types which differ in the connections and flow arrangements. Type I has flat covers over the spiral channels. The media flow countercurrent through the channels via the connections in the center and at the periphery. This type is used to exchange heat between media without phase changes such as liquid-liquid, gas-liquid, or gas-gas. One stream enters at the center of the unit and flows from inside outward. The other stream enters at the periphery and flows towards the center. Thus the counter flow is achieved.

Type II is designed for cross flow operation. One channel is completely seal welded, while the other is open along both sheet metal edges. The passage

with the medium in spiral flow is welded shut on each side, and the medium in cross flow passes through the open spiral annulus. This type is mainly used as a surface condenser in evaporating plants. It is also highly effective as a vaporizer. Two spiral bodies are often built into the same jacket and are mounted below each other.

Type III, the third standard type is in principle similar to type I with alternately welded up channels, but type III is provided with a specially designed top cover. This type of heat exchanger is mainly intended for condensing vapors with sub-cooling of condensate and non condensable gases. The top cover, therefore, has a special distribution cone where the vapor is distributed to the uncovered spiral turns in order to maintain a constant vapor velocity along the channel opening. The figure 2.5 and 2.6 presents the types of spiral plate.




Plate 2.5: Spiral plate heat exchanger Type I




Plate 2.6: Spiral plate heat exchanger Type II

2.3.2 LAMELLA TYPE EXCHANGERS

The lamella type of heat exchanger consists of a set of parallel, welded, thin plates channels are lamellae placed longitudinally in a shell. It is a modification of the floating-type shell-and-tube heat exchanger. These flattened tubes, called lamellae are made up of two strips of plates, profiled and spot- or seam-welded together in a continuous operation. The forming of the strips creates space inside the lamellae and bosses acting as spacers for the flow sections outside the lamellae on the shell side. The lamellae are welded together at both ends by joining the ends with steel bars in between, depending on the space required between lamellae. Both ends of the lamella bundle are joined by peripheral welds to the channel cover which at the outer ends is welded to the inlet and outlet nozzle. The lamella side thus completely sealed in by welds. At the fixed end, the channel cover is equipped with an outside flange ring which is bolted to the shell flange. Figure 2.7 presents the lamella heat exchanger.

2.4 SHELL AND TUBE HEAT EXCHANGER

2.4.1 SHELL

The shell barrel must be straight and have no out-of-roundness, as a tightly fitting tube bundle must be inserted in it. Most shell and head barrels greater than about 450 mm in inside diameter are rolled from plate, and a complete shell barrel may comprise several smaller barrels, or strakes, welded together end to end. If there is any out-of-roundness, individual strakes are rerolled after welding the longitudinal seams. The longitudinal seams of adjoining strakes are always staggered. The inside diameter of a rolled shell should not exceed the design inside diameter by more than 3.2 mm (1/8 in) as determined by circumferential measurement. All internal welds must be made flush.

When welding large nozzles to the shell "shrinkage" may occur at the nozzle/shell junction and effective measures, such as the use of temporary stiffening, must be taken to avoid it. Shrinkage reduces the shell diameter at the nozzle/shell junction so that the baffle diameter must be reduced accordingly. The increased clearance between baffle and shell may result in reduced thermal performance.

Standard pipe less than 450 mm in diameter is usually available, and this will be used for the shell and head barrels instead of rolled plate. Depending on the fabricators roll capacity, at thicknesses of the order of 80 mm and greater or large thickness/diameter ratios, it may be necessary to use forged instead of rolled barrels.

When an expensive barrel metal is required for corrosion resistance purposes only, the barrel is formed from the selected metal if its thickness is less than about 15 mm. Above this the use of clad metal should be investigated, as it may provide a cost saving. The clad metal will usually comprise a steel plate, having a thickness suitable for the pressure and temperature conditions with a layer of the required

corrosion resistant metal, about 3 mm thick, bonded to it. The cladding may be applied by explosive, roll bonding, or weld deposition methods. TEMA specifies minimum shell and head barrel thicknesses, which depend on barrel diameter, metal and TEMA class.

2.4.2 TUBE

The tubes are the basic component of the shell and tube heat exchanger, providing the heat transfer surface between one fluid flowing inside the tube and other fluid flowing across the outside of the tubes. The tube may be seamless or welded and most commonly made of copper or steel alloys. Other alloys of nickel, titanium, or aluminum may also be used for specific applications.

The tube may be either bare or extended surface on the outside. Extended or enhanced surface tubes are used when one fluid has a substantially lower heat transfer coefficient than the other fluid. doubly enhanced tubes that is, with enhancement both inside and outside are available that can reduce the size and cost of the exchanger. Extended surfaces (finned tubes) provide two to four times as much heat transfer area on the outside as the corresponding bare tube, and this area helps to offset a lower outside heat transfer coefficient.

Tubes should be able to withstand the following

1. Operating temperature and pressure on both sides
2. Thermal stresses due to the differential thermal expansion between the shell and the tube bundle
3. Corrosive nature of both the shell-side and the tube-side fluids

There are two types of tubes: straight tubes and U-tubes. The tubes are further classified as

1. Plain tubes
2. Finned tubes
3. Duplex or bimetallic tubes
4. Enhanced surface tubes

2.4.3 BAFFLE

Baffles are used to support tubes, enable a desirable velocity to be maintained for the shell side fluid, and prevent failure of tubes due to flow-induced vibration.

There are two types of baffles:

- plate
- rod


Plate baffles may be single-segmental, double-segmental, or triple-segmental, as shown in Figure.



**Single Segmental
Baffles**



**Double Segmental
Baffles**



**Triple Segmental
Baffles**

The Baffle spacing is the centerline-to-centerline distance between adjacent baffles. It is the most vital parameter in Shell and tube heat exchanger design. The TEMA standards specify the minimum baffle spacing as one-fifth of the shell

inside diameter or 2 in., whichever is greater. Closer spacing will result in poor bundle penetration by the shell side fluid and difficulty in mechanically cleaning the outsides of the tubes. Furthermore, a low baffle spacing results in a poor stream distribution as will be explained later.

CHAPTER THREE

MATERIALS AND METHODS

3.1 MATERIALS

The table below shows the materials used for the design

Materials	Dimension/Specification	Application
Stainless steel pipe	89mm	Used as the shell
Copper pipe	18mm	Used as the pipe
Stainless steel plate	20mm	Used as the baffle
Mild steel pipe	92mm	Used as a housing for the insulator and protects the shell
313CDW Hose	8mm	Used to link the pipe to the pump
U curves	18mm	Used with the pipe
Water pump	0.5hp	Used for pumping water
¼" mild steel pipe	-	Used as the stand for the exchanger
A & B Chemical	2litres	Used as the

		insulator
Paint	1 litre	Used to paint the whole project

3.2 Methods

The conceptual design of the project was started with the use of Ansys 14.00 for the modeling of the project and Ansys 18.0 for the simulation

For the simulation to be possible, initial conditions are very important.


The designed exchanger was modeled with the following initial boundary condition were applied.

Intake & Exhaust System

Combustion Air Consumption	m ³ /min	27
Max. Intake Restriction	KPa	5
Exhaust Temperature (Before Turbo)	°C	660
Exhaust Temperature (After Turbo)	°C	510
Max. Exhaust Back Pressure	Kpa	5
Exhaust Gas Flow	m ³ /min	33
Turbo Bellows Diameter	mm	DN100-150
Exhaust Flange Diameter	mm	DN150

initial conditions for the exhaust system (adapted from the engine manual)

Also, the flow table shown below is used in the identification of other four parameters




Flow tube table

parameters	Flow rate(m ³ /s)	Velocity(m/s)	Area (m ²)	Diameter (m)
Pump	5.833e-4	0.726	8.04e-4	0.032
Tube	2.9165e-4	3.713	7.855e-5	0.01
Shell	0.55	96.83	5.68	0.085

3.2.1 Modelling of the exhaust

The modelling of the exhaust was done with Ansys 14.0 and the result is as shown below



Result of simulated exhaust pip

3.2.7 DESIGN CALCULATIONS

MARCUISE WATER PUMP MODEL QB60

3.4.1 SPECIFICATIONS FOR PUMP

$$H_{\max} = 35\text{m}$$

$$Q_{\max} = 351/\text{min}$$

$$V = 220\text{v}$$

$$F = 50$$

$$A = 2.5\text{A}$$

$$P = 0.5$$

$$S = 2850 \text{ r/min}$$

$$S \text{ Head} = 8\text{m}$$

$$\text{Size} = 1 \text{ by } 1$$

Pipe = 2.5m

D= 8.9cm

Taking the efficiency of pump as = 0.85

$$\text{Average flow rate} = 0.85 \times 35 = 29.75 \text{L/min} \frac{29.75}{60} = \mathbf{0.496 \text{L/sec}}$$

Taking the transfer to be at the minimum of 350°C , and the tube size is that of $3\text{cm}=0.03\text{m}$, than the water temperature is at room temperature = 25°C , and the properties of water is extracted from steam table as follow:

Knowing that the outlet temperature of water is not to exceed 100°C , we take a counter flow exchanger design with the following parameters, i.e

$$T_{c1} = 25^{\circ}\text{C}$$

$$T_{c2} = 100^{\circ}\text{C}$$

$$T_{h1} = 350^{\circ}\text{C}$$

$$T_{h2} = ?$$

$$C_{pc} = ?$$

$$C_{pw} = 4.2 \text{kJ/kgK}$$

$$M_w = 35 \text{ L/min} = 0.035 \text{m}^3/\text{min}$$

$$M_e = 33 \text{m}^3$$

we know power confirmed by the pump is $P = IV = 220 \times 2.5 = 550 \text{w}$

The pressure with which the water flows at a mean height of $3.5\text{m} = P$

$$\mathbf{P = pgh = 1000 \times 9.81 \times 3.5 = 34.335 \text{kPa}}$$

Now the temperature vs length profile of the exchanger is shown below.

By energy balance, $M_w C_{p_w}(t_{c2} - t_{c1}) = M_{ex} C_{p_{ex}}(th_1 - th_2)$

By putting the values in the above equation:

$$0.035 \times 4.2(100 - 25) = 3.3(1.0049)(350 - th_2)$$

$$th_2 = 350 - 0.333 = 349.67^\circ\text{C}$$

$$\Phi_m = (\Phi_1 - \Phi_2) / (\ln \Phi_1 / \Phi_2)$$

$$\Phi_m = 349.84^\circ\text{C}$$

$$Q = UA \Phi_m$$

$$A = \pi DL$$

$$D = 0.089\text{m}$$

$$A = \pi * 0.089 * L$$

$$Q = 11.025\text{kJ}$$

$$U = 54\text{W/m}^\circ\text{C}$$

$$11.025 = 54 * \pi * 0.089 * L * 349.84$$

$$L = 0.021\text{m} = 21.00\text{cm}$$

Using n for the length of the tube

Using n for the length of the shell

3.4.2 DESIGN FOR SHELL

$$\text{area of shell} = \frac{\pi d^2}{4}$$

where $d = 89\text{cm} = 0.089\text{m}$

$$\text{area} = \frac{\pi \times 0.089^2}{4}$$

$$\text{area} = 0.02853\text{m}^2$$

Temperature of the water assumed to be at room temperature

T_{c1} = temperature of cold water

T_{c2} = temperature of hot water

T_{h1} = temperature of hot exhaust

T_{h2} = temperature of cold exhaust

M_w = mass flow rate of water

M_e = mass flow rate of exhaust

C_{pe} = heat capacity of exhaust

C_{pw} = heat capacity of water

Θ_m = logarithmic mean temperature difference

$$\Theta_1 = t_{h1} - t_{c2}$$

$$\Theta_2 = t_{h2} - t_{c1}$$



Q = quantity of heat transferred

For maximum heat, the counterflow arrangement is used.

From the manual of the water pump engine, the mass flow of water

$$M_c = 33\text{m}^3/\text{min} = 0.55\text{m}^3/\text{sec}$$

By energy balance;

$$M_c c_{pe} (t_{h1} - t_{h2}) = M_w c_{pe} (t_{c1} - t_{c2})$$

$$0.55 \times 1.033(350 - t_{h2}) = 0.0002916 \times 4.2 \times 73 =$$

$$0.5682(350 - t_{h2}) = 0.00012472(73)$$

$$0.582(350 - t_{h2}) = 0.0894$$

$$350 - t_{h2} = 0.1536$$

$$t_{h2} = 349.852$$

$$\text{Now } \Theta_m = \frac{\Theta_1 - \Theta_2}{\ln \frac{\Theta_1}{\Theta_2}}$$

$$\Theta_1 = 350 - 100 = 250^\circ\text{C}$$

$$\Theta_2 = 349.85 - 47 = 322.85^\circ\text{C}$$

$$\Theta_m = \frac{250 - 322.85}{\ln \frac{250}{322.85}} = \frac{-72.85}{\ln 0.7744}$$

$$\Theta_m = 284.9^\circ\text{C}$$

$$Q = m_c c_{pe} (t_{h1} - t_{h2}) = 0.55 \times 1.033 \times (350 - 349.85) = 0.0852\text{kw}/\text{m}^2\text{C}$$

$$Q = U_n A \Theta_m \times F$$

where F is the connection factor

$$U_o = \text{overall heat transfer coefficient } \frac{1}{h_o} + \frac{1}{k} = 6.352 \text{ m}^2 \text{ c/w}$$

$$\frac{1}{U} = \frac{1}{h} X \frac{di}{do} + \frac{\Delta x}{KA}$$

For negligible thickness of shell

$$\text{Overall heat transfer} = \frac{1}{lm} X \frac{di}{do} + \frac{ox}{KA}$$

$$\text{for negligible thickness of shells} = \frac{1}{h_o} + \frac{1}{k} = 6.352 \text{ m}^2 \text{ c/w R}$$

$$k = 54 \text{ m}^2 \text{ c/w}$$

$$U = 5.684kw/m^2 \text{ } ^\circ\text{c}$$

$$85.2 = 5.684 X 0.032L X \pi X 284.9 X 0.70$$

$$L = \frac{0.525}{0.70} = 75 \text{ cm}$$

$$Re = \frac{UD}{V}$$

For water at 100°C = 373 k, from appendix 1

$$V = 279 X 10^{-6} \mu \frac{s}{m^3}$$

$$Re = \frac{0.726 X 0.032 X 10^6}{279} = 83.27$$

For shell

$$Re_{shell} = \frac{UD}{V}$$

From appendix two, by interpolation V at 623K (350°C) is calculated as $55.48 \text{ m}^3/\text{s} X 10^{-6}$

$$Re_{shell} = \frac{96.83 \times 0.085 \times 10^6}{55.48} = 148351 \text{ (turbulent)}$$

3.4.3 DESIGN FOR FOULING FACTOR (TUBE)

From table 4.2, $F = 0.00009 \text{ m}^{20} \text{ c/w}$

$$F = (a \ln \frac{\frac{(1-p)}{1-RP}}{(1-R) \ln \frac{(2-p)(b-a)}{(2-p)(b+a)}})$$

$$a = \sqrt{R^2 + H}$$

$$b = RH$$

$$R = \frac{th2 - th1}{th2 - tc2}$$

$$P = \frac{1}{R}$$

$$a = \sqrt{R^2 + H} = \sqrt{R^2 + 1} = \sqrt{486.52^2 + 1}$$

$$a = 487.02$$

$$P = \frac{349.85 - 350}{27 - 350} = \frac{-0.15}{-323} = 0.000464$$

$$B = R+1 = 486.5+1 = 487.5$$

$$F = \frac{4.87.02 \ln \left(\frac{1 - 0.000464}{1 - 0.000464 \times 486.5} \right)}{(1 - 486.5) \ln \frac{2 - 0.000464(489.5)}{2 - 0.000464(487.5 + 489.5)}}$$

$$F = \frac{-4.89}{-4.85} = 0.70$$

Length of tube = Area of shell = $n\pi dl$

$$L = \frac{A}{n\pi d} = \frac{0.00568}{2 \times 3.142 \times 0.01}$$

length of each tube = 9.04 cm

3.4.3 DESIGN FOR INSULATION

Thickness for insulation

$$r = \frac{h}{k} = \frac{0.352}{54}$$

$$8.9 + 3 = 11.9 = 0.119m$$

$$h = 6.426$$

$$k = 54$$

$$r_0 = 0.119m = 11.9cm$$

$$\Delta R = r_0 - r_1 = 11.9 - 8.9 = 3.0 \text{ cm}$$

CHAPTER FOUR

Results and Discussion

4.1 RESULTS

4.1.1 the designed and fabricated exchanger

Figure 4.1 shows the designed and fabricated exchanger



Figure 4.1 the designed shell and tube heat exchanger

4.2 The testing of the exchanger

The exchanger was tested with the generator that it was designed for and the results obtained is presented in table 4.1

Table 4.1 shows the result obtained when the exchanger was tested

Parameters	Designed results	Tested results
Final temperature of exhaust(°C)	349.66	245.62
Final temperature of water(°C)	100	87.53
Exchanger's effectiveness	0.226	0.1874

The relative efficiency of the exchanger is calculated as;

$$\text{Relative efficiency} = \frac{\text{effectiveness of the tested exchanger}}{\text{effectiveness of the designed exchanger}}$$

$$\text{Relative efficiency} = \frac{0.1874}{0.226}$$

$$= 0.8292 \text{ or } 82.92\%$$

4.2 Discussion

The result of the tested exchanger has some disparities compared to the designed results of the exchanger, these may be due to the following reasons as highlighted below;

1. the generator was not working at full capacity because of students being on holiday and this might have reduced the exhaust flow rate designed.
2. The baffle material might have caused some constrictions in the the flow of the exhaust in the tube.
3. Approximation errors during design calculations and errors in the insulation thickness may be responsible for such a disparity.

However, relative efficiency of 0.8292 shows that the design was satisfactory.

CHAPTER FIVE

Conclusion and recommendation

5.1 Conclusion

The results obtained from the testing of the heat exchanger show that the exchanger is satisfactory. Most exchangers' designs are not as efficient as this. However, the fact that the exchanger was designed into specifications is more than an enough reason to appreciate design and engineering. The project has also widened my knowledge and my ingenuity as an engineering student. The project has made me appreciate the use of software in designing and made me learn and understand the use of Ansys software.

5.2 Recommendation

I recommend that further work be carried on the heat exchanger such as implementing and integrating the exchanger with flow meters so that the inlet and outlet flow parameters are easily known as this will make the exchanger a better one.

A similar exchanger may be designed to boil the water to a super-saturated level, such an exchanger finds an application in power plants.

Works may also be carried out on the selection of header tube and on the separation of the baffles of the exchangers

Design may be done with other Computational Fluid Dynamics (CFD) software so that comparison can be made to know the best software for the design of heat exchangers especially a shell and tube heat exchanger.

REFERENCES

- Andre L.H. Costa, Eduardo M. Queiroz, (2008)** “Design optimization of shell-and-tube heat exchangers”, Applied Thermal Engineering 28 (2008) 1798–1805.
- ASME Section II, (2004)** “For Material Specifications,” 2004.
- Boles, Y. A. (2006).** Thermodynamics: An Engineering Approach. McGraw-Hill.
- B.V. Babu, S.A. Munawarb,** “Differential evolution strategies for optimal design of shell and tube heat exchanger”, Chemical Engineering Science 62 (2007) 3720 – 3739.
- Chang, T.-B. (2009).** Enhancing the heat transfer performance of triangular-pitch shell-and-tube evaporators using an interior spray technique. Research Gate, 14 -19.
- D. Q. Kern, (1965)** “Process Heat Transfer”, McGraw-Hill Book Company, Int. ed. 1965
- Dennis R. Moss, (2003)** “Pressure Vessel Design Manual,” 3rd Edition, Chapter 1-4, Elsevier, Amsterdam, 2003.
- Ebieto, C.E. and Eke G.B., (2012)** “Performance Analysis of Shell and Tube Heat Exchangers using Miscible System: A case study”, Journal of Emerging Trends in Engineering and Applied Sciences, 2012 3 (5), pp. 899-903.al
- G.N. Xie, Q.W. Wang , M. Zeng, L.Q. Luo, (2007)** “Heat transfer analysis for shell and tube heat exchanger with experimental data by artificial neural networks approach”, Applied Thermal Engineering 27 (2007) 1096–1104.

Indian Standard (IS: 4503-1967): Specification for Shell and Tube Type Heat Exchangers, BIS 2007, New Delhi.

Jiangfeng Guo, Lin Cheng, Mingtian Xu, (2009) “Optimization design of shell and tube heat exchanger by entropy generation minimization and genetic algorithm”, Applied Thermal Engineering 29 (2009) 2954–2960.

José M. Ponce-Ortega, Medardo Serna-González, Arturo Jiménez-Gutiérrez, (2009) “Use of genetic algorithms for the optimal design of shell and tube heat exchanger”, Applied Thermal Engineering 29 (2009) 203–209.

Kurmi, 2006. Design of Machine Elements

M. Fesanghary, E. Damangir, I. Soleimani, (2009) “Design optimization of shell and tube heat exchanger using global sensitivity analysis and harmony search algorithm”, Applied Thermal Engineering 29 (2009) 1026–1031.

M. M. El-Fawal, A. A. Fahmy and B. M. Taher, “Modelling of Economical Design of Shell and tube heat exchanger Using Specified Pressure Drop”, Journal of American Science.

M.Serna and A.Jimenez, “A compact formulation of the Bell Delaware method for Heat Exchanger design and optimization”, Chemical Engineering Research and Design, 83(A5): 539–550.

R. Hosseini, A. Hosseini-Ghaffar, M. Soltani (2007), “Experimental determination of shell side heat transfer coefficient and pressure drop for an oil cooler shell and tube heat exchanger with three different tube bundles”, Applied Thermal Engineering 27 (2007) 1001–1008..

R. K. Sinnott, Coulson & Richardsons, (1999) Chemical Engineering: “Chemical Engineering Design” (volume 6), Butterworth-Heinemann, 3rd ed. 1999.

R. K. Shah, (2003) “Fundamentals of Heat Exchanger Design,” 2nd Edition, Chapter 1-5, Wiley, Hoboken, 2003. doi:10.1002/9780470172605

R. Mukherjee, (2004) "Practical Thermal Design of Shell and Heat Exchangers,"
2nd Edition, Chapter 1-5, 8, Begell House, Redding, 2004

Rajagopal Thundil Karuppa Raj, Srikanth Ganne, (2012) "Shell side numerical analysis of a shell and tube heat exchanger considering the effect of baffle inclination angle on a fluid flow", Thundil Karuppa Raj, R., et al: Shell side numerical analysis of shell and tube heat exchangers, Thermal science: Year 2012, Vol.16, No.4, pp 1165-1174

Rajeev Mukharji, (1998) "Effective design of shell and tube heat exchanger",
American Institute of Chemical Engineering, 1988.

Ramesh K. Shah, D. P. (2003). Fundamentals of Heat Exchanger Design. New
Jersey and Canada: John Wiley & sons Inc

Resat Selbas, Onder Kızılkın, Marcus Reppich, (2006) "A new design approach for shell and tube heat exchanger using genetic algorithms from economic point of view", Chemical Engineering and Processing 45 (2006) 268-275

Sadik kakac, (2002)"Heat Exchangers Selection, Rating and Thermal Design",
2002.

Sepehr Sanaye, Hassan Hajabdollahi, (2010) "Multi-objective optimization of shell and tube heat exchanger", Applied Thermal Engineering 30 (2010) 1937-1945.

Su Thet Mon Than, Khin Aung Lin, Mi Sandar Mon, (2008) "Heat Exchanger design", World Academy of Science, Engineering and Technology 46 2008.

TEMA, "Standards of the Tubular Exchanger Manufacturer's Association (TEMA), (1999)" 8th Edition, Section 1-5, 7-10, Tubular Exchanger Manufacturers Association, Inc., New York, 1999

Usman UR Rehman, "Heat transfer optimization of shell and tube heat exchanger through CFD studies", Master thesis in innovative and sustainable Chemical engineering from Chalmers University of Technology.

V.K. Patel, R.V. Rao, "Design optimization of shell and tube heat exchanger using particle swarm optimization technique", Applied Thermal

Wolverine, "Wolverine Tube Heat Transfer Data Book, (1984)" 2nd Edition, Wolverine Tube Inc., Decatur, 1984, pp. 60-71, 85-95.

Yusuf Ali Kara, Ozbilen Guraras, (2004) "A computer program for designing of shell and tube heat exchanger", Applied Thermal Engineering 24(2004) 1797-1805.

Zahid H. Ayub, (2005) "A new chart method for evaluating single phase shell side heat transfer coefficient in a single segmental Shell and tube heat exchanger", Applied Thermal Engineering 25 (2005) 2412-2420.

ZHANG Xiao-jun1, W. X.-L.-R. (2010). Numerical Simulation of Flow Field in Shell side of Heat Exchanger in Nuclear Power Plant. CNKI, 50-62.

Appendix

Appendix 1

The values of μ , k , c_p , and Pr are not strongly pressure-dependent and may be used over a fairly wide range of pressures

T, K	ρ kg/m ³	c_p kJ/kg·°C	$\mu \times 10^{-5}$ kg/m·s	$\nu \times 10^6$ m ² /s	k W/m·°C	$\alpha \times 10^4$ m ² /kg	Pr
100	3.6013	1.0266	0.6924	1.923	0.009246	0.02501	0.770
150	2.3677	1.0069	1.0283	4.343	0.013735	0.05745	0.753
200	1.7564	1.0061	1.3289	7.460	0.01809	0.10165	0.739
250	1.4128	1.0053	1.5990	11.31	0.02227	0.15675	0.722
300	1.1774	1.0057	1.8462	15.69	0.02624	0.22160	0.708
350	0.9980	1.0090	2.075	20.76	0.03005	0.2983	0.697
400	0.8826	1.0140	2.286	25.90	0.03365	0.3760	0.689
450	0.7833	1.0207	2.484	31.71	0.03707	0.4522	0.683
500	0.7048	1.0295	2.671	37.90	0.04038	0.5264	0.680
550	0.6423	1.0392	2.843	44.34	0.04360	0.6032	0.680
600	0.5979	1.0551	3.018	51.34	0.04659	0.6812	0.680
650	0.5630	1.0635	3.177	58.51	0.04933	0.7578	0.682
700	0.5350	1.0752	3.332	66.25	0.05230	0.8472	0.684
750	0.4709	1.0856	3.481	73.91	0.05509	1.0774	0.686
800	0.4405	1.0978	3.625	82.29	0.05779	1.1951	0.689
850	0.4149	1.1095	3.765	90.75	0.06028	1.3097	0.692
900	0.3925	1.1212	3.899	99.3	0.06279	1.4271	0.696
950	0.3715	1.1321	4.023	108.2	0.06525	1.5510	0.699
1000	0.3524	1.1417	4.152	117.8	0.06752	1.6779	0.702
1100	0.3204	1.160	4.44	138.6	0.0732	1.969	0.704
1200	0.2947	1.179	4.69	159.1	0.0782	2.251	0.707
1300	0.2707	1.197	4.93	182.1	0.0837	2.583	0.705
1400	0.2515	1.214	5.17	205.5	0.0891	2.920	0.705
1500	0.2357	1.230	5.40	229.1	0.0946	3.262	0.705
1600	0.2211	1.248	5.63	254.5	0.100	3.609	0.705
1700	0.2082	1.267	5.85	280.5	0.105	3.977	0.705
1800	0.1970	1.287	6.07	308.1	0.111	4.379	0.704
1900	0.1858	1.309	6.29	338.5	0.117	4.811	0.704
2000	0.1762	1.336	6.50	369.0	0.124	5.260	0.702
2100	0.1682	1.372	6.72	399.6	0.131	5.715	0.700
2200	0.1602	1.418	6.93	432.6	0.139	6.120	0.707
2300	0.1538	1.452	7.14	464.0	0.149	6.540	0.710
2400	0.1459	1.574	7.35	504.0	0.161	7.020	0.718
2500	0.1394	1.658	7.57	543.5	0.175	7.441	0.730

°F	°C	c_p kJ/kg·°C	ρ kg/m ³	μ kg/m·s	k W/m·°C	Pr	$\frac{g\beta\rho^2c_p}{\mu k}$ 1/m ³ ·°C
32	0	4.225	999.8	1.79×10^{-3}	0.566	13.25	
40	4.44	4.208	999.8	1.55	0.575	11.35	1.91×10^9
50	10	4.195	999.2	1.31	0.585	9.40	6.34×10^9
60	15.56	4.186	998.6	1.12	0.595	7.88	1.08×10^{10}
70	21.11	4.179	997.4	9.8×10^{-4}	0.604	6.78	1.46×10^{10}
80	26.67	4.179	995.8	8.6	0.614	5.85	1.91×10^{10}
90	32.22	4.174	994.9	7.65	0.623	5.12	2.48×10^{10}
100	37.78	4.174	993.0	6.82	0.630	4.53	3.3×10^{10}
110	43.33	4.174	990.6	6.16	0.637	4.04	4.19×10^{10}
120	48.89	4.174	988.8	5.62	0.644	3.64	4.89×10^{10}
130	54.44	4.179	985.7	5.13	0.649	3.30	5.66×10^{10}
140	60	4.179	983.3	4.71	0.654	3.01	6.48×10^{10}
150	65.56	4.183	980.3	4.3	0.659	2.73	7.62×10^{10}
160	71.11	4.186	977.3	4.01	0.665	2.53	8.84×10^{10}
170	76.67	4.191	973.7	3.72	0.668	2.33	9.85×10^{10}
180	82.22	4.195	970.2	3.47	0.673	2.16	1.09×10^{11}
190	87.78	4.199	966.7	3.27	0.675	2.03	
200	93.33	4.204	963.2	3.06	0.678	1.90	
220	104.4	4.216	955.1	2.67	0.684	1.66	
240	115.6	4.229	946.7	2.44	0.685	1.51	
260	126.7	4.250	937.2	2.19	0.685	1.36	
280	137.8	4.271	928.1	1.98	0.685	1.24	
300	148.9	4.296	918.0	1.86	0.684	1.17	
350	176.7	4.371	890.4	1.57	0.677	1.02	
400	204.4	4.467	859.4	1.36	0.665	1.00	
450	232.2	4.585	825.7	1.20	0.646	0.85	
500	260	4.731	785.2	1.07	0.616	0.83	
550	287.7	5.024	735.5	9.51×10^{-5}			
600	315.6	5.703	678.7	8.68			

Adapted to SI units from A. I. Brown and S. M. Marco, *Introduction to Heat Transfer*, 3rd ed. New York: McGraw-Hill, 1958.

DESIGN FOR THE FOULING FACTOR

Type of fluid	Fouling factor, h · ft ² · °F/Btu	m ² · °C/W
Seawater, below 125°F	0.0005	0.00009
Above 125°F	0.001	0.002
Treated boiler feedwater above 125°F	0.001	0.0002
Fuel oil	0.005	0.0009
Quenching oil	0.004	0.0007
Alcohol vapors	0.0005	0.00009
Steam, non-oil-bearing	0.0005	0.00009
Industrial air	0.002	0.0004
Refrigerating liquid	0.001	0.0002

Table 4.2 Fouling factors for some fluid (j.pholman)

An extract on the parameters from the generator manual

Intake & Exhaust System

Combustion Air Consumption	m ³ /min	27
Max. Intake Restriction	KPa	5
Exhaust Temperature (Before Turbo)	°C	660
Exhaust Temperature (After Turbo)	°C	510
Max. Exhaust Back Pressure	Kpa	5
Exhaust Gas Flow	m ³ /min	33
Turbo Bellows Diameter	mm	DN100-150
Exhaust Flange Diameter	mm	DN150

- a = local variable for equation 7
 a_s = shell flow area, ft^2
 a_t = tube flow area, ft^2
 A = area for heat transfer, ft^2
 b = local variable for equation 7
 B = baffle spacing, ft
 c' = shell clearance, ft
 C_{p_s} = shell side heat capacity, $\frac{\text{Btu}}{\text{lbm} \cdot ^\circ\text{F}}$
 C_{p_t} = tube side heat capacity, $\frac{\text{Btu}}{\text{lbm} \cdot ^\circ\text{F}}$
 d = inner tube diameter, ft
 d_o = outer tube diameter, ft
 D_e = equivalent shell diameter, ft
 D = shell diameter, ft
 F = correction factor for 1 shell pass and 2 tube passes
 h_t = tube side convective heat transfer coefficient, $\frac{\text{Btu}}{\text{hr} \cdot \text{ft}^2 \cdot ^\circ\text{F}}$
 h_s = shell side convective heat transfer coefficient, $\frac{\text{Btu}}{\text{hr} \cdot \text{ft}^2 \cdot ^\circ\text{F}}$
 k = thermal conductivity of tube material, $\frac{\text{Btu}}{\text{hr} \cdot \text{ft} \cdot ^\circ\text{F}}$
 L = tube length, ft
 \dot{m}_s = shell mass flow rate, $\frac{\text{lbm}}{\text{s}}$
 \dot{m}_t = tube mass flow rate, $\frac{\text{lbm}}{\text{s}}$
 n_t = number of tubes
 N_p = number of tube passes
 Nu_{shell} = shell side Nusselt number
 Nu_{tube} = tube side Nusselt number
 P = local variable for equation 7
 Pr_{shell} = shell side Prandtl number
 Pr_{tube} = tube side Prandtl number
 P_t = tube pitch, ft